



**Westworth Village**

The Hidden Jewel of the Metroplex.

---

# 2017 Annual Drinking Water Quality Report

**City of Westworth Village  
Water Department**

 817.710.2506

 [cityofwestworth.com/utility](http://cityofwestworth.com/utility)

 311 Burton Hill Rd.  
Westworth Village, TX 76114

City of Westworth Village (PWS 2200131)  
Consumer Confidence Report

In accordance with TCEQ (Texas Commission on Environmental Quality) regulations we are providing the attached information regarding water quality. This is a routine procedure, not an indication of any problems with our water supply. For your protection TCEQ requires that we monitor numerous substances that may be present in water. The attached charts list these possible contaminants, the maximum allowed levels, test results. In compliance with TCEQ regulations, the Westworth Water Department performs daily water monitoring activities to ensure that we can provide our customers with safe drinking water. From time to time your drinking water may have differences in odor and taste. We work with Fort Worth Water Department, who supplies our water, to minimize these occurrences. Despite these changes the water remains safe for consumption.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly or immunocompromised persons, such as those undergoing chemotherapy for cancer; those who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline at (800) 426-4791.

### Public Participation Opportunities:

When: Monday - Friday  
Time: 8:00 AM - 5:00 PM  
Location: 311 Burton Hill Rd. (*City Hall*)  
Phone: 817-710-2506

To learn about future public meetings (concerning your drinking water), or to request to schedule one, please call us.

### En Español

Este informe incluye información importante sobre el agua potable. Si tiene preguntas o comentarios sobre éste informe en español, favor de llamar al tel. (817) 710-2506, para hablar con una persona bilingue en español.

### Our Drinking Water Meets or Exceeds All Federal (EPA) Drinking Water Requirements

This report is a summary of the quality of the water we provide our customers. The analysis was made by using the data from the most recent U.S. Environmental Protection Agency (EPA) required tests and is presented in the attached pages. We hope this information helps you become more knowledgeable about what's in your drinking water.

**WATER SOURCES:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water before treatment include: microbes, inorganic contaminants, pesticides, herbicides, radioactive contaminants, and organic chemical contaminants.

### Where do we get our drinking water?

Our drinking water is obtained from SURFACE water sources. It comes from the following Lake/River/Reservoir/Aquifer: LAKE WORTH, RICHLAND CHAMBERS RESERVOIR, EAGLE MOUNTAIN LAKE, CLEAR FORK TRINITY RIVER, CEDAR CREEK RESERVOIR. A Source Water Susceptibility Assessment for your drinking water source (s) is currently being updated by the Texas Commission on Environmental Quality. This information describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information contained in the assessment allows us to focus our source water protection strategies. Some of this source water assessment information will be available later this year on Texas Drinking Water Watch at [www.tceq.texas.gov](http://www.tceq.texas.gov). For more information on source water assessments and protection efforts at our system, please contact us.

# 2017 Consumer Confidence Report

## for Public Water System CITY OF WESTWORTH VILLAGE (PWS 2200131)

This is your water quality report for January 1 to December 31, 2017

*City of Westworth Village provides surface water from Fort Worth PWS 2200012, located in Tarrant County.*

Definitions and Abbreviations	The following tables contain scientific terms and measures, some of which may require explanation.
Action Level:	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Action Level Goal (ALG):	The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Level 1 Assessment:	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment:	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MFL:	million fibers per liter (a measure of asbestos)
mrem:	millirems per year (a measure of radiation absorbed by the body)
na:	not applicable.
NTU:	nephelometric turbidity units (a measure of turbidity)
pCi/L:	picocuries per liter (a measure of radioactivity)
ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
Ppq:	parts per quadrillion, or picograms per liter (pg/L)
Ppt:	parts per trillion, or nanograms per liter (ng/L)
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

# Information About Your Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.



In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

# Information About Source Water

City of Westworth Village purchases water from City of Fort Worth located in Tarrant County.

TCEQ completed a Source Water Susceptibility for all drinking water systems that own their sources. This report describes the susceptibility and types of constituents that may come into contact with the drinking water source based on human activities and natural conditions. The system(s) from which we purchase our water received the assessment report. For more information on source water assessments and protection efforts at our system contact Joseph Alvarez 817-710-2504.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	06/09/2016	1.3	1.3	0.6373	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	06/09/2016	0	15	1.2	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

## 2017 Water Quality Test Results

Disinfection By-Products	Collection Date	Highest Level or Average Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)	2017	12	5.3 - 19.6	No goal for the total	60	ppb	N	By-product of drinking water disinfection.

\* The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year'

Total Trihalomethanes (TTHM)	2017	12	7.96 - 13.8	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
------------------------------	------	----	-------------	-----------------------	----	-----	---	--

\* The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year'

Inorganic Contaminants	Collection Date	Highest Level or Average Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Nitrate [measured as Nitrogen]	2017	0.3	0.207 - 0.3	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

## Disinfectant Residual

Disinfectant Residual	Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	Source in Drinking Water
Chloramines	2017	2.51	0.90 – 3.90	4	4	ppm	N	Water additive used to control microbes.

# Drinking Water Quality Test Results

Contaminant	Measure	MCL	MCLG	Your water	Violation	Common Sources of Substance
Turbidity	NTU	TT=1 TT= <b>Lowest monthly % of samples ≤ 0.3 NTU</b>	N/A	0.6 99.8%	No	Soil runoff (Turbidity is a measure of the cloudiness of water. It is monitored because it is a good indicator of the effectiveness of the filtration system.)

Contaminant	Measure	MCL	MCLG	Your water	Range	Violation	Common Sources of Substance
Total Coliforms (including fecal coliform & E. coli)	% positive samples	Presence in 5% or less of monthly samples	0	0	0	No	Coliforms are naturally present in the environment as well as feces; fecal coliforms and E. coli only come from human and animal fecal waste.

Contaminant	Measure	MCL	MCLG	Your water	Range	Violation	Common Sources of Substance
Beta particles & photon emitters <sup>1</sup>	pCi/L	50	0	5.6	4.4 to 5.6	No	Decay of natural and man-made deposits of certain minerals that are radioactive and may emit forms of radiation known as photons and beta radiation
Combined Radium (-226 & -228)	pCi/L	5	0	2.5	NA	No	Erosion of natural deposits
Uranium	ppb	30	0	1.1	0 to 1.1	No	Erosion of natural deposits
Arsenic	ppb	10	0	2	0 to 2	No	Erosion of natural deposits; runoff from orchards, runoff from glass and electronics production waste
Atrazine	ppb	3	3	0.1	0.0 to 0.1	No	Runoff from herbicide used on row crops
Barium	ppm	2	2	0.08	0.06 to 0.08	No	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium (Total)	ppb	100	100	1.6	0 to 1.6	No	Discharge from steel and pulp mills, erosion of natural deposits
Cyanide	ppb	200	200	57.0	0 to 57.0	No	Discharge from plastic and fertilizer factories; discharge from steel and metal factories
Di (2-Ethylhexyl) phthalate	ppb	6	0	1.2	0 to 1.2	No	Discharge from rubber and chemical factories
Fluoride	ppm	4	4	0.66	0.32 to 0.66	No	Water additive which promotes strong teeth; erosion of natural deposits; discharge from fertilizer and aluminum factories
Nitrate (measured as Nitrogen)	ppm	10	10	0.76	0.13 to 0.76	No	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrite (measured as Nitrogen)	ppm	1	1	0.03	0.01 to 0.03	No	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Simazine	ppb	4	4	0.06	0 to 0.06	No	Herbicide runoff
Bromate	ppb	10	0	2	0 to 13	No	By-product of drinking water disinfection.
Haloacetic Acids	ppb	60	N/A	12	5.3 to 19.6	No	By-product of drinking water disinfection
Total Trihalomethanes	ppb	80	N/A	12	7.96 to 13.8	No	By-product of drinking water disinfection

Contaminant	Measure	MDRL	MCLG	Your water	Range	Violation	Common Sources of Substance
Chloramines	ppm	4	4	2.51	0.9 to 3.9	No	Water additive used to control microbes

Contaminant	MCL	MCLG	High	Average	Low	Violation	Common Sources of Substance
Total Organic Carbon	TT = % removal	N/A	1	1	1	No	Naturally occurring
It is used to determine disinfection by-product precursors. Fort Worth was in compliance with all monitoring and treatment technique requirements for disinfection by-product precursors.							

# Abbreviations Used in Tables

**MCL:** Maximum Contaminant Level – the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**MCLG:** Maximum Contaminant Level Goal – the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**MRDL:** Maximum Residual Disinfectant Level – the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**MRDLG:** Maximum Residual Disinfectant Level Goal – the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**N/A:** not applicable/does not apply

**NTU:** Nephelometric Turbidity Unit; a measure of water turbidity or clarity

**pCi/L** – Picocuries per liter; a measure of radioactivity

**ppb** – Parts per billion or micrograms per liter ( $\mu\text{g/L}$ ) **ppm** – Parts per million or milligrams per liter (mg/L)

**TT:** Treatment Technique – a required process intended to reduce the level of a contaminant in drinking water

## Unregulated Contaminants

<sup>4</sup> Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

Contaminant	Measure	MRDL	MRDLG	Your Water	Range of Detects	Common Sources of Substance
Chloral Hydrate	ppb	Not regulated	0	0.70	0.18 to 0.70	By-product of drinking water disinfection
Bromoform	ppb	Not regulated	0	5.83	1.19 to 5.83	By-products of drinking water disinfection; not regulated individually; included in Total Trihalomethanes
Bromodichloromethane	ppb	Not regulated	0	7.81	3.37 to 7.81	
Chloroform	ppb	Not regulated	0.07	7.96	2.58 to 7.96	
Dibromochloromethane	ppb	Not regulated	0.06	8.51	4.33 to 8.51	
Dibromoacetic Acid	ppb	Not regulated	N/A	15.3	11.9 to 15.3	By-products of drinking water disinfection; not regulated individually; included in Haloacetic Acids
Dichloroacetic Acid	ppb	Not regulated	0	8.60	4.70 to 8.60	
Monobromoacetic Acid	ppb	Not regulated	N/A	3.10	1.60 to 3.10	
Monochloroacetic Acid	ppb	Not regulated	0.07	0	0 to 0	
Trichloroacetic Acid	ppb	Not regulated	0.02	1.60	0 to 1.60	

## Secondary Constituents

These items do not relate to public health but rather to the aesthetic effects. These items are often important to industry.

Item	Measure	Your water
Bicarbonate	ppm	108 to 144
Calcium	ppm	37.4 to 50.6
Chloride	ppm	11.6 to 36.1
Conductivity	$\mu\text{mhos/cm}$	299 to 456
pH	units	7.8 to 8.6
Magnesium	ppm	2.69 to 7.78
Sodium	ppm	9.57 to 25.9
Sulfate	ppm	24.8 to 34.4
Total Alkalinity as $\text{CaCO}_3$	ppm	108 to 145
Total Dissolved Solids	ppm	116 to 255
Total Hardness as $\text{CaCO}_3$	ppm	113 to 157
Total Hardness in Grains	grains/gallon	7 to 9

## Emergency Interconnection

From April 24 to April 25, 2017, Fort Worth used the emergency interconnection with the Trinity River Authority of Texas-Tarrant Water Supply Project to supply water to the Centreport portion of the Fort Worth distribution system while repairs were made. The volume of water was subsequently repaid to TRA-TCWSP the next day via the emergency interconnection.

To obtain the TRA-TCWSP water quality data, please contact the Westworth Village Water Department 817-710-2506.

## Microorganism Testing Shows Low Detections in Raw Water

Tarrant Regional Water District monitors the raw water at all intake sites for *Cryptosporidium*, *Giardia Lamblia* and viruses. The source is human and animal fecal waste in the watershed.

The 2017 sampling showed low level detections of *Giardia Lamblia*, which is common in surface water. *Cryptosporidium* and viruses were not

detected in any of the samples. (The table below indicates when detections were found in each raw water source. Including the table in your water quality report is not required.) Viruses are treated through disinfection processes. *Cryptosporidium* and *Giardia Lamblia* are removed through disinfection and/or filtration.

Intake location	<i>Giardia Lamblia</i>	<i>Cryptosporidium</i>	Adenovirus	Enterovirus
Richland-Chambers Reservoir	Not detected	Not detected	Not detected	Not detected
Cedar Creek Lake	March	Not detected	Not detected	Not detected
Lake Benbrook	May	Not detected	Not detected	Not detected
Eagle Mountain Lake	January	Not detected	Not detected	Not detected
Lake Worth	January	Not detected	Not detected	Not detected
Clearfork of Trinity River	January, February, April, May, June	Not detected	Not detected	Not detected

## TCEQ Assesses Raw Water Supplies for Susceptibility

Fort Worth uses surface water from Lake Worth, Eagle Mountain Lake, Lake Bridgeport, Richland Chambers Reservoir, Cedar Creek Reservoir, Lake Benbrook and the Clear Fork Trinity River.

Fort Worth owns Lake Worth. The U.S. Army Corps of Engineers is responsible for Benbrook Lake. The other four lakes are owned and operated by Tarrant Regional Water District.

The Texas Commission on Environmental Quality completed an assessment of Fort Worth's source waters. TCEQ classified the risk to our source waters as high for most contaminants.

High susceptibility means there are activities near the source water a or watershed make it very likely that chemical constituents may come into contact with the source water. It does not mean that there are any health risks present.